

<u>CANAL FACTORY TALK</u>	<u>IRCUITO</u>	<u>ITM</u>	<u>CLIENTE</u>	<u>GABINETE</u>	<u>PDU1 EATON 7 AMPERIOS</u>	<u>PDU2 EATON 8 AMPERIOS</u>	<u>TOTAL KW</u>	<u>PDU1 EATON 7 AMPERIOS</u>	<u>PDU2 EATON 8 AMPERIOS</u>	<u>TOTAL KW</u>
Ch15.ActivePower [kW]	C-15	1X32	OSCE	P07	6.50	6.60	2.88	6.50	6.40	2.84
Ch18.ActivePower [kW]	C-18	1X25	OSCE	P07	0.00	0.00	0.00	0.00	0.00	0.00
Ch23.ActivePower [kW]	C-23	1X16	OSCE	C01	2.20	1.60	0.84	2.20	1.60	0.84
Ch25.ActivePower [kW]	C-25	1X32	OSCE	C05	0.00	0.00	0.00	0.00	0.00	0.00
Ch34.ActivePower [kW]	C-34	1X25	OSCE	C02	1.30	0.40	0.37	1.30	0.40	0.37
Ch35.ActivePower [kW]	C-35	1X25	OSCE	C03	0.00	0.00	0.00	0.00	0.00	0.00
Ch36.ActivePower [kW]	C-36	1X25	OSCE	C04	0.00	0.00	0.00	0.00	0.00	0.00
Ch37.ActivePower [kW]	C-37	1X25	OSCE	C04	0.00	0.00	0.00	0.00	0.00	0.00
Ch38.ActivePower [kW]	C-38	1X25	OSCE	C06	0.20	2.80	0.66	0.20	2.90	0.68
Ch39.ActivePower [kW]	C-39	1X25	OSCE	C06	0.20	2.30	0.55	0.20	2.30	0.55
Ch48.ActivePower [kW]	C -48	1X16	OSCE	C01	3.70	2.90	1.45	3.70	2.90	1.45
Ch49.ActivePower [kW]	C -49	1X16	OSCE	C03	1.00	1.20	0.48	1.00	1.20	0.48
Ch50.ActivePower [kW]	C -50	1X16	OSCE	C02	3.40	4.70	1.78	3.40	4.70	1.78
Ch01.ActivePower [kW]	C-1	1X32	OSCE	C08	5.20	5.60	2.38	5.20	5.60	2.38
Ch02.ActivePower [kW]	C-2	1X32	OSCE	C08	5.20	6.00	2.46	5.20	6.00	2.46
Ch03.ActivePower [kW]	C-3	1X32	OSCE	C09	4.40	4.70	2.00	4.40	4.70	2.00
Ch04.ActivePower [kW]	C-4	1X32	OSCE	C09	5.20	5.40	2.33	5.20	5.50	2.35
Ch05.ActivePower [kW]	C-5	1X32	OSCE	C10	1.90	3.60	1.21	1.90	3.70	1.23
Ch06.ActivePower [kW]	C-6	1X32	OSCE	C10	9.10	4.40	2.97	9.10	4.50	2.99