

EVALUACION Proceso N°SEL-0068-2023-OTL/PETROPERÚ – 2da Convocatoria SOLPED 1000120024 "ADQUISICIÓN DE VALVULAS DE ACERO PARA REFINERÍA TALARA (ÍTEM PAQUETE N°1)"			POSTOR 1		POSTOR 2	
Item	DESCRIPCION DEL BIEN SOLICITADO	DESCRIPCION DEL BIEN OFERTADO	NELKAREL S.A.C.		TECNOLOGÍA INGENIERÍA Y COMERCIO INDUSTRIAL S.A.C. – TÉCNICO INDUSTRIAL S.A.C.	
			S/N		S/N	
			Propone	Observaciones	Propone	Observaciones
1.1	58-050-100479 VALVE TIPO/MODELO : GATE. MAT. FAB. PRINCIPAL : CAST IRON (CI) DIA. NOM. : 4 INCH CLASS: 125 CONEXION: FLANGED NORMA/EE.TT.: ASTM A126 CLASS B. ----- BODY AND BONNET: CAST IRON ASTM A126 CLASS B. BOLTED BONNET. OUTSIDE SCREW AND YOKE (OS AND Y). TRIM BRONZE: SEAT AND STEM ASTM B62. SOLDIED SEATS. SOLID WEDGE. WITH HANDWHEEL OPERATED. FLANGE END DIMENSION AND DRILLING: ASME B16.1. FLANGE FACE-TO-FACE: ASME B16.10. MARKING: MSS SP-25.DESIGN: MSS SP-70. QUALITY CERTIFICATION INDICATING CHEMICAL COMPOSITION. MECHANICAL PROPERTIES AND TEST PRESSURE. ----- INFORME DE USO DE MARCA N°GDTE-0364-2022 (REFINERÍA TALARA) MARCA: CRANE, STOCKHAM, WALWORTH, DSI, BONEY FORGE, DOUGLAS CHERO, OMB, DSI, NEWAY, BRAY, KEYSTONE, APOLLO, XOMOX, AHAUS (FLOWSERVE), JC, VELAN, DURCO (FLOWSERVE), AZ VALVE, HANCOCK (TYCO), GESTRA WARREN, SWAGELOK, NEWAY y FLOWSERVE.	58-050-100479 VALVE GATE 4" CI 125LB FLNGD	SI CUMPLE REQUISITOS MINIMOS	NINGUNA	NO CUMPLE REQUISITOS MINIMOS	LA MARCA REX NO FIGURA ENTRE LAS MARCAS DEL INFORME GDTE-0364-2022.
1.2	58-050-100493 VALVE TIPO/MODELO : GATE MAT. FAB. PRINCIPAL : CAST CARBON STEEL (CCS) DIA. NOM. : 2 INCH P. MAX. W. : 150 LB CONEXION : FLANGED - SPOT FACING NORMA/EE.TT. : ASTM A216 WCB ----- OIL OR OIL VAPOR. FLANGED ASME B16.5 150 LB. BODY AND BONNET ASTM A216 GRADE WCB. TRIM 8 (13% Cr/Co-Cr) : STEM STAINLESS STEEL ASTM A276 TYPE 410. SEAT RING ASTM A217 GRADE CA15. BOLTED BONNET. OUTSIDE SCREW AND YOKE (OS AND Y). SEAL WELDED SEAT RINGS. FLEXIBLE WEDGE DISC ASTM A276 TYPE 410. BODY SEAT RING HARD FACING. SPOT FACING. RAISED FACE AND DRILLED FLANGES ANSI B16.5. ACCORDING TO : ASME B16.34/API 598/API 600/MSS SP-25/MSS SP-55/MSS SP-61/MSS SP-82. ----- INFORME DE USO DE MARCA N°GDTE-0364-2022 (REFINERÍA TALARA) MARCA: CRANE, STOCKHAM, WALWORTH, DSI, BONEY FORGE, DOUGLAS CHERO, OMB, DSI, NEWAY, BRAY, KEYSTONE, APOLLO, XOMOX, AHAUS (FLOWSERVE), JC, VELAN, DURCO (FLOWSERVE), AZ VALVE, HANCOCK (TYCO), GESTRA WARREN, SWAGELOK, NEWAY y FLOWSERVE.	58-050-100493 VALVE GATE 2" CCS 150LB FLNGD	SI CUMPLE REQUISITOS MINIMOS	NINGUNA	NO CUMPLE REQUISITOS MINIMOS	LA MARCA REX NO FIGURA ENTRE LAS MARCAS DEL INFORME GDTE-0364-2022.
1.3	58-050-100494 VALVE TIPO/MODELO : GATE MAT. FAB. PRINCIPAL : CAST CARBON STEEL (CCS) DIA. NOM. : 2 INCH P. MAX. W. : 300 LB CONEXION : FLANGED - SPOT FACING NORMA/EE.TT. : ASTM A216 WCB ----- OIL OR OIL VAPOR. FLANGED ASME B16.5 300 LB. BODY AND BONNET ASTM A216 GRADE WCB. TRIM 8 (13% Cr/Co-Cr) : STEM STAINLESS STEEL ASTM A276 TYPE 410. SEAT RING ASTM A217 GRADE CA15. BOLTED BONNET. OUTSIDE SCREW AND YOKE (OS AND Y). SEAL WELDED SEAT RINGS. FLEXIBLE WEDGE DISC ASTM A276 TYPE 410. BODY SEAT RING HARD FACING. SPOT FACING. RAISED FACE AND DRILLED FLANGES ANSI B16.5. ACCORDING TO : ASME B16.34/API 598/API 600/MSS SP-25/MSS SP-55/MSS SP-61/MSS SP-82. ----- INFORME DE USO DE MARCA N°GDTE-0364-2022 (REFINERÍA TALARA) MARCA: CRANE, STOCKHAM, WALWORTH, DSI, BONEY FORGE, DOUGLAS CHERO, OMB, DSI, NEWAY, BRAY, KEYSTONE, APOLLO, XOMOX, AHAUS (FLOWSERVE), JC, VELAN, DURCO (FLOWSERVE), AZ VALVE, HANCOCK (TYCO), GESTRA WARREN, SWAGELOK, NEWAY y FLOWSERVE.	58-050-100494 VALVE GATE 2" CCS 300LB FLNGD	SI CUMPLE REQUISITOS MINIMOS	NINGUNA	NO CUMPLE REQUISITOS MINIMOS	LA MARCA REX NO FIGURA ENTRE LAS MARCAS DEL INFORME GDTE-0364-2022.

EVALUACION Proceso N°SEL-0068-2023-OTL/PETROPERÚ – 2da Convocatoria SOLPED 1000120024 "ADQUISICIÓN DE VALVULAS DE ACERO PARA REFINERÍA TALARA (ÍTEM PAQUETE N°1)"			POSTOR 1		POSTOR 2	
Item	DESCRIPCION DEL BIEN SOLICITADO	DESCRIPCION DEL BIEN OFERTADO	NELKAREL S.A.C.		TECNOLOGÍA INGENIERÍA Y COMERCIO INDUSTRIAL S.A.C. – TÉCNICO INDUSTRIAL S.A.C.	
			S/N		S/N	
			Propone	Observaciones	Propone	Observaciones
1.4	<p>58-050-100497 VALVE TIPO/MODELO : GATE MAT. FAB. PRINCIPAL : CAST CARBON STEEL (CCS) DIA. NOM. : 3 INCH P. MAX. W. : 150 LB CONEXION : FLANGED - SPOT FACING NORMA/EE.TT. : ASTM A216 WCB ----- OIL OR OIL VAPOR. FLANGED ASME B16.5 150 LB. BODY AND BONNET ASTM A216 GRADE WCB. TRIM 8 (13% Cr/Co-Cr) : STEM STAINLESS STEEL ASTM A276 TYPE 410. SEAT RING ASTM A217 GRADE CA15. BOLTED BONNET. OUTSIDE SCREW AND YOKE (OS AND Y). SEAL WELDED SEAT RINGS. FLEXIBLE WEDGE DISC ASTM A276 TYPE 410. BODY SEAT RING HARD FACING. SPOT FACING. RAISED FACE AND DRILLED FLANGES ANSI B16.5. ACCORDING TO : ASME B16.34/API 598/API 600/MSS SP-25/MSS SP-55/MSS SP-61/MSS SP-82. ----- INFORME DE USO DE MARCA N°GDTE-0364-2022 (REFINERÍA TALARA) MARCA: CRANE, STOCKHAM, WALWORTH, DSI, BONEY FORGE, DOUGLAS CHERO, OMB, DSI, NEWAY, BRAY, KEYSTONE, APOLLO, XOMOX, AHAUS (FLOWSERVE), JC, VELAN, DURCO (FLOWSERVE), AZ VALVE, HANCOCK (TYCO), GESTRA WARREN, SWAGELOK, NEWAY y FLOWSERVE.</p>	<p>58-050-100497 VALVE GATE 3" CCS 150LB FLNGD</p>	SI CUMPLE REQUISITOS MINIMOS	NINGUNA	NO CUMPLE REQUISITOS MINIMOS	LA MARCA REX NO FIGURA ENTRE LAS MARCAS DEL INFORME GDTE-0364-2022.
1.5	<p>58-050-100504 VALVE TIPO/MODELO : GATE MAT. FAB. PRINCIPAL : CAST CARBON STEEL (CCS) DIA. NOM. : 4 INCH P. MAX. W. : 150 LB CONEXION : FLANGED - SPOT FACING NORMA/EE.TT. : ASTM A216 WCB ----- OIL OR OIL VAPOR. FLANGE ASME B16.5 150 LB. BODY AND BONNET : ASTM A216 GRADE WCB. STEM : STAINLESS STEEL ASTM A276 TYPE 410. WEDGE : ASTM A216 GRADE WCB TRIM 8 (13% Cr). SEAT RING : ASTM A217 GRADE CA15 - TRIM 8 (Co-Cr A). BOLTED BONNET. OUTSIDE SCREW AND YOKE (OS AND Y). FLEXIBLE WEDGE. BODY SEAT RING HARD FACING. RAISED FACE AND DRILLED FLANGES ANSI B16.5. ACCORDING TO : ASME B16.34 / API 598 / API 600 / MSS SP-25 / MSS SP-55 / MSS SP-61 / MSS SP-82. ----- INFORME DE USO DE MARCA N°GDTE-0364-2022 (REFINERÍA TALARA) MARCA: CRANE, STOCKHAM, WALWORTH, DSI, BONEY FORGE, DOUGLAS CHERO, OMB, DSI, NEWAY, BRAY, KEYSTONE, APOLLO, XOMOX, AHAUS (FLOWSERVE), JC, VELAN, DURCO (FLOWSERVE), AZ VALVE, HANCOCK (TYCO), GESTRA WARREN, SWAGELOK, NEWAY y FLOWSERVE.</p>	<p>58-050-100504 VALVE GATE 4" CCS 150LB FLNGD</p>	SI CUMPLE REQUISITOS MINIMOS	NINGUNA	NO CUMPLE REQUISITOS MINIMOS	LA MARCA REX NO FIGURA ENTRE LAS MARCAS DEL INFORME GDTE-0364-2022.
1.6	<p>58-050-100548 VALVE TIPO/MODELO : GATE MAT. FAB. PRINCIPAL : BRONZE DIA. NOM. : 1 INCH P. MAX. W. : 150 LB CONEXION : THREADED NORMA/EE.TT. : ASTM B62 ALLOY C83600 ----- BODY, BONNET, DISC AND STEM BRONZE. ASTM B62 ALLOY C83600. BRASS TRIM. INSIDE SCREW NOW RISING STEM(ISNRS). SOLID WEDGE DISC. SCREW BONNET. SCREWED ENDS. INTEGRAL SEAT. ACCORDING TO : ASME B16.34/API 598/MSS SP-25/MSS SP-80/MSS SP-82. ----- INFORME DE USO DE MARCA N°GDTE-0364-2022 (REFINERÍA TALARA) MARCA: CRANE, STOCKHAM, WALWORTH, DSI, BONEY FORGE, DOUGLAS CHERO, OMB, DSI, NEWAY, BRAY, KEYSTONE, APOLLO, XOMOX, AHAUS (FLOWSERVE), JC, VELAN, DURCO (FLOWSERVE), AZ VALVE, HANCOCK (TYCO), GESTRA WARREN, SWAGELOK, NEWAY y FLOWSERVE.</p>	<p>58-050-100548 VALVE GATE 1" BRNZ 150LB THRD</p>	SI CUMPLE REQUISITOS MINIMOS	NINGUNA	NO CUMPLE REQUISITOS MINIMOS	LA MARCA CIMBERIO NO FIGURA ENTRE LAS MARCAS DEL INFORME GDTE-0364-2022.

EVALUACION Proceso N°SEL-0068-2023-OTL/PETROPERÚ – 2da Convocatoria SOLPED 1000120024 "ADQUISICIÓN DE VALVULAS DE ACERO PARA REFINERÍA TALARA (ÍTEM PAQUETE N°1)"			POSTOR 1		POSTOR 2	
Item	DESCRIPCION DEL BIEN SOLICITADO	DESCRIPCION DEL BIEN OFERTADO	NELKAREL S.A.C.		TECNOLOGÍA INGENIERÍA Y COMERCIO INDUSTRIAL S.A.C. – TÉCNICO INDUSTRIAL S.A.C.	
			S/N		S/N	
			Propone	Observaciones	Propone	Observaciones
1.7	58-050-100550 VALVE TIPO/MODELO : GATE MAT. FAB. PRINCIPAL : BRONZE DIA. NOM. : 2 INCH P. MAX. W. : 150 LB CONEXION : THREADED NORMA/EE.TT. : ASTM B62 ALLOY C83600 ----- BODY, BONNET, DISC AND STEM BRONZE. ASTM B62 ALLOY C83600. BRASS TRIM. INSIDE SCREW NOW RISING STEM(ISNRS). SOLID WEDGE DISC. SCREW BONNET. SCREWED ENDS. INTEGRAL SEAT. ACCORDING TO : ASME B16.34/API 598/MSS SP-25/MSS SP-80/MSS SP-82. ----- INFORME DE USO DE MARCA N°GDTE-0364-2022 (REFINERÍA TALARA) MARCA: CRANE, STOCKHAM, WALWORTH, DSI, BONEY FORGE, DOUGLAS CHERO, OMB, DSI, NEWAY, BRAY, KEYSTONE, APOLLO, XOMOX, AHAUS (FLOWSERVE), JC, VELAN, DURCO (FLOWSERVE), AZ VALVE, HANCOCK (TYCO), GESTRA WARREN, SWAGELOK, NEWAY y FLOWSERVE.	58-050-100550 VALVE GATE 2" BRNZ 150LB THRD	SI CUMPLE REQUISITOS MINIMOS	NINGUNA	NO CUMPLE REQUISITOS MINIMOS	LA MARCA CIMBERIO NO FIGURA ENTRE LAS MARCAS DEL INFORME GDTE-0364-2022.
1.8	58-050-100553 VALVE TIPO/MODELO : GATE MAT. FAB. PRINCIPAL : CAST IRON (CI) DIA. NOM. : 3/4 INCH P. MAX. W. : 150 LB CONEXIÓN : THREADED (THRD) NORMA/EE.TT. : ASTM A126 GR B ----- BODY AND BONNET CAST IRON ASTM A126 GRADE B. IRON TRIM. INSIDE SCREW RISING STEM(ISRS). SOLID WEDGE DISC. CLAMP BONNET. INTEGRAL SEAT. ACCORDING TO: ASME B16.34 / MSS SP-70 / MSS SP 25 / MSS SP 55 / API 598. ----- INFORME DE USO DE MARCA N°GDTE-0364-2022 (REFINERÍA TALARA) MARCA: CRANE, STOCKHAM, WALWORTH, DSI, BONEY FORGE, DOUGLAS CHERO, OMB, DSI, NEWAY, BRAY, KEYSTONE, APOLLO, XOMOX, AHAUS (FLOWSERVE), JC, VELAN, DURCO (FLOWSERVE), AZ VALVE, HANCOCK (TYCO), GESTRA WARREN, SWAGELOK, NEWAY y FLOWSERVE.	58-050-100553 VALVE GATE 3/4" CI 150LB THRD	SI CUMPLE REQUISITOS MINIMOS	NINGUNA	NO CUMPLE REQUISITOS MINIMOS	LA MARCA REX NO FIGURA ENTRE LAS MARCAS DEL INFORME GDTE-0364-2022.
1.9	58-050-100561 VALVE TIPO/MODELO : GATE MAT. FAB. PRINCIPAL : FORGED CARBON STEEL DIA. NOM. : 1-1/2 IN P. MAX. W. : 800 LB CONEXION : THREADED NORMA/EE.TT. : ASTM A105 ----- CONVENTIONAL PORT. BODY AND BONNET FORGED STEEL ASTM A105. BOLTED BONNET. OUTSIDE SCREW AND YOKE(OS AND Y). TRIM 8 (13% Cr/Co-Cr) : STEM STAINLESS STEEL ASTM A276 TYPE 410. SEAT RING ASTM A182 GRADE F6. SEAT RING STAINLESS STEEL AISI 410 STELLITE FACED. SOLID WEDGE DISC ASTM A276 TYPE 410. ACCORDING TO : ASME B16.34/API 598/API 600/MSS SP-25/MSS SP-55/MSS SP-61/MSS SP-82. ----- INFORME DE USO DE MARCA N°GDTE-0364-2022 (REFINERÍA TALARA) MARCA: CRANE, STOCKHAM, WALWORTH, DSI, BONEY FORGE, DOUGLAS CHERO, OMB, DSI, NEWAY, BRAY, KEYSTONE, APOLLO, XOMOX, AHAUS (FLOWSERVE), JC, VELAN, DURCO (FLOWSERVE), AZ VALVE, HANCOCK (TYCO), GESTRA WARREN, SWAGELOK, NEWAY y FLOWSERVE.	58-050-100561 VALVE GATE 1-1/2" FCS 800LB THRD	SI CUMPLE REQUISITOS MINIMOS	NINGUNA	NO CUMPLE REQUISITOS MINIMOS	LA MARCA REX NO FIGURA ENTRE LAS MARCAS DEL INFORME GDTE-0364-2022.
1.10	58-050-100562 VALVE TIPO/MODELO : GATE MAT. FAB. PRINCIPAL : FORGED CARBON STEEL DIA. NOM. : 2 INCH P. MAX. W. : 800 LB CONEXION : THREADED NORMA/EE.TT. : ASTM A105 ----- CONVENTIONAL PORT. BODY AND BONNET FORGED STEEL ASTM A105. BOLTED BONNET. OUTSIDE SCREW AND YOKE(OS AND Y). TRIM 8 (13% Cr/ Co-Cr) : STEM STAINLESS STEEL ASTM A276 TYPE 410. SEAT RING ASTM A182 GRADE F6. SOLID WEDGE DISC ASTM A276 TYPE 410. ACCORDING TO : ASME B16.34/API 598/API 602/MSS SP-25/MSS SP-55/MSS SP-61/MSS SP-82. ----- INFORME DE USO DE MARCA N°GDTE-0364-2022 (REFINERÍA TALARA) MARCA: CRANE, STOCKHAM, WALWORTH, DSI, BONEY FORGE, DOUGLAS CHERO, OMB, DSI, NEWAY, BRAY, KEYSTONE, APOLLO, XOMOX, AHAUS (FLOWSERVE), JC, VELAN, DURCO (FLOWSERVE), AZ VALVE, HANCOCK (TYCO), GESTRA WARREN, SWAGELOK, NEWAY y FLOWSERVE.	58-050-100562 VALVE GATE 2" FCS 800LB THRD	SI CUMPLE REQUISITOS MINIMOS	NINGUNA	NO CUMPLE REQUISITOS MINIMOS	LA MARCA REX NO FIGURA ENTRE LAS MARCAS DEL INFORME GDTE-0364-2022.

EVALUACION Proceso N°SEL-0068-2023-OTL/PETROPERÚ – 2da Convocatoria SOLPED 1000120024 "ADQUISICIÓN DE VALVULAS DE ACERO PARA REFINERÍA TALARA (ÍTEM PAQUETE N°1)"			POSTOR 1		POSTOR 2	
Item	DESCRIPCION DEL BIEN SOLICITADO	DESCRIPCION DEL BIEN OFERTADO	NELKAREL S.A.C.		TECNOLOGÍA INGENIERÍA Y COMERCIO INDUSTRIAL S.A.C. – TÉCNICO INDUSTRIAL S.A.C.	
			S/N		S/N	
			Propone	Observaciones	Propone	Observaciones
1.11	58-100-100566 VALVE TIPO/MODELO : GLOBE MAT. FAB. PRINCIPAL : CAST CARBON STEEL (CCS) DIA. NOM. : 2 INCH P. MAX. W. : 150 LB CONEXION : FLANGED - SPOT FACING NORMA/EE.TT. : ASTM A216 WCB ----- BODY AND BONNET : ASTM A216 GRADE WCB. STEM : STAINLESS STEEL ASTM A276 TYPE 410. WEDGE : ASTM A216 GRADE WCB - TRIM 8 (13% Cr). SEAT RING :ASTM A217 GRADE CA15 - TRIM 8 (Co-Cr A). BOLTED BONNET. OUTSIDE SCREW AND YOKE (OS AND Y). RAISED FACE AND DRILLED FLANGES ANSI B16.5. ACCORDING TO : ASME B16.34/API 598/API 600/MSS SP-25/MSS SP-55/MSS SP-61/MSS SP-82. ----- INFORME DE USO DE MARCA N°GDTE-0364-2022 (REFINERÍA TALARA) MARCA: CRANE, STOCKHAM, WALWORTH, DSI, BONEY FORGE, DOUGLAS CHERO, OMB, DSI, NEWAY, BRAY, KEYSTONE, APOLLO, XOMOX, AHAUS (FLOWSERVE), JC, VELAN, DURCO (FLOWSERVE), AZ VALVE, HANCOCK (TYCO), GESTRA WARREN, SWAGELOK, NEWAY y FLOWSERVE.	58-100-100566 VALVE GLOBE 2" CCS 150LB FLNGD	SI CUMPLE REQUISITOS MINIMOS	NINGUNA	NO CUMPLE REQUISITOS MINIMOS	LA MARCA REX NO FIGURA ENTRE LAS MARCAS DEL INFORME GDTE-0364-2022.
1.12	58-250-100629 VALVE TIPO/MODELO : CHECK – SWING MAT. FAB. PRINCIPAL : CAST CARBON STEEL DIA. NOM. : 2 INCH P. MAX. W. : 150 LB CONEXION : FLANGED - SPOT FACING NORMA/EE.TT. : ASTM A216 GRADE WCB ----- BODY, CAP AND SWING ASTM A216 GRADE WCB. TRIM 8 (13% Cr/Co-Cr). HORIZONTAL OR VERTICAL. BOLTED CAP. RAISED FACE DRILLED FLANGES ANSI B16.5. CLASS 150. ACCORDING TO : ASME B16.34/API 594/API 598/MSS SP-25/MSS SP-55/MSS SP-61/MSS SP-82. ----- INFORME DE USO DE MARCA N°GDTE-0364-2022 (REFINERÍA TALARA) MARCA: CRANE, STOCKHAM, WALWORTH, DSI, BONEY FORGE, DOUGLAS CHERO, OMB, DSI, NEWAY, BRAY, KEYSTONE, APOLLO, XOMOX, AHAUS (FLOWSERVE), JC, VELAN, DURCO (FLOWSERVE), AZ VALVE, HANCOCK (TYCO), GESTRA WARREN, SWAGELOK, NEWAY y FLOWSERVE.	58-250-100629 VALVE CHECK 2" CCS 150LB FLNGD	SI CUMPLE REQUISITOS MINIMOS	NINGUNA	NO CUMPLE REQUISITOS MINIMOS	LA MARCA REX NO FIGURA ENTRE LAS MARCAS DEL INFORME GDTE-0364-2022.
Aprobado por Coordinación Optimización Monitoreo y Control			SI CUMPLE REQUISITOS MINIMOS		NO CUMPLE REQUISITOS MINIMOS, LAS MARCAS OFERTADAS NO ESTÁN INCLUIDAS EN EL INFORME GDTE-0364-2022	
Jefatura Inegniería de Mantenimiento						